

Déclaration des performances

Declaration of Performance



DOP_0107

N° UE 305/2011 Déclaration des performances fr

Code d'identification unique du produit type : Dispositifs de retenue électromagnétique pour portes battantes

GROOM BEMS.V2, GROOM BEMS.OF. V2

Usage (s) prévu (s): Prescription de déclenchement pour les portes coupe-feu et étanches aux fumées à fermeture automatique

Fabricant : Fermetures GROOM SAS - BP 80256 ZI de l'Aumallerie F- 35302 Fougères

Système(s) d'évaluation et de vérification de la constance des performances : Système 1.

Norme harmonisée : EN1155 :1997 + A1 : 2002 + AC : 2006

Organisme notifié : AFNOR CERTIFICATION 0333

Performance(s) déclarée(s) :

Caractéristique essentielles	Performances	Norme européenne harmonisée
Capacité de déclenchement	Catégorie d'utilisation grade 3 Force du ferme-porte EN 3-5 Aptitude pour une utilisation sur des blocs-portes résistant au feu et/ou étanches aux fumées grade 1 Sécurité grade 1	EN1155 :1997 + A1 :2002 + AC : 2006
Endurance de la capacité de déclenchement	Endurance 500000 cycles d'essai grade 8 Résistance à la corrosion haute classe 3	
Substances dangereuses	Substances extrêmement préoccupantes < valeurs limites	

Les performances du produit identifié ci-dessus sont conformes aux performances déclarées. Conformément au règlement (UE) no 305/2011, la présente déclaration des performances est établie sous la seule responsabilité du fabricant mentionné ci-dessus.

Signé pour le fabricant et en son nom par :

Anthony, le 13 octobre 2025

Eric Pourquey
Directeur

FERMETURES GROOM
2-6 Avenue du Général de Gaulle
92160 ANTONY
Tél 01.58.43.04.02 - Fax 01.58.43.04.03
SIREN : 332 617 901

Déclaration des performances

Declaration of Performance



DOP_0107

EU Nr. 305/2011 Declaration of Performance en

Unique identification code of the product-type: Electrically powered hold open devices for swing doors

GROOM BEMS.V2, GROOM BEMS.OF. V2

Intended use/es: On fire and smoke compartmentation doors to fulfil the ability to release requirement.

Manufacturer: Fermetures GROOM SAS - BP 80256 ZI de l'Aumallerie F- 35302 Fougères

System/s of assessment and verification of constancy of performance (AVCP): System 1

Harmonised standard: EN 1155:1997 + A1:2002 + AC: 2006

Notified body/ies: AFNOR CERTIFICATION 0333

Performance/s:

Essential characteristics	Performance	Harmonised technical specification
Ability to release	Category of use Grade 3 Door closer size EN 3-5 Suitability for fire/smoke door use Grade 1 Safety Grade 1	EN1155 :1997 + A1 :2002 + AC : 2006
Durability of ability to release	Durability 500000 cycles Grade 8 high corrosion resistance grade 3	
Dangerous substances	Substances of very high concern < maximum permissible levels	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Anthony, le 13 octobre 2025

Eric Pourquey
Directeur

FERMETURES GROOM
2-6 Avenue du Général de Gaulle
92160 ANTONY
Tél 01.58.43.04.02 - Fax 01.58.43.04.03
SIREN : 332 617 901